



INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

Ver. May 12, 2011

Contact Information

Primary: John Slevin

Enterprise Systems Group
Lead Network Infrastructure & VOIP SE
Information Transport Systems
john.slevin@fscj.edu
[904-997-2993](tel:904-997-2993)

Secondary: John D. (J.D.) Hudnall

Enterprise Systems Group
Network Infrastructure Engineer
Information Transport Systems Specialist
john.d.hudnall@fscj.edu
[904-997-2943](tel:904-997-2943)

Tertiary: Ron Smith

Enterprise Systems Group
AVP of Computing Infrastructure,
Security, Compliance & CSO
ron.smith@fscj.edu
[904-997-2997](tel:904-997-2997)

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

(Blank Page)

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

1. Introduction	4
1.1. Purpose	4
1.2. Applicable Standards	5
TIA/EIA	5
NFPA	5
ISO/IEC	5
1.3. Additional Support	5
1.3.1. PanGen™ System Warranty	5
1.3.2. Contractor Agreement	5
2. Telecommunication Network System Requirements	6
2.1. Description	6
2.2. Supported Applications	6
2.3. Additional Requirements	7
3. Work Area Subsystem	8
3.1. Patch Cords and Modular Connectors	8
3.1.1. Copper	8
3.1.1.1. Category 6 UTP	8
3.1.1.2. Additional Copper Cabling Connectors	9
3.1.2. Fiber Optic	9
3.2. Outlets and Surface Mount Boxes	10
Faceplates	10
Modular Furniture Faceplates	11
Faceplate Frames and Inserts	11
Stainless Steel Faceplates	11
Surface Mount Boxes	11
Other Outlet Components	12
3.3. Surface Raceway and Vertical Outlet Pole	13
3.3.1. Multi-Channel (Coming Soon)	13
3.3.2. Single Channel (Coming Soon)	13
3.3.3. Outlet Pole	13
4. Horizontal Cabling Subsystem	14
4.1. Copper UTP Cable	15
Category 6 UTP Cable	15
4.2. Fiber Cable	18
Horizontal Distances - Optical Fiber Links	18
Specifications	18
Performance	18
5. Telecommunications Room	20
5.1. Cable Termination Hardware	20
5.1.1. Category 6 Unshielded Twisted Pair UTP	20
5.1.1.1. Modular Patch Panels and Cords	20
Fiber Termination Hardware	21
5.1.1.2. Fiber Optic Connectors and Patch Cords	21
5.2. Fiber Optic Equipment	22
Enclosures	22
5.3. Cable Management	22

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

5.3.1. Vertical Cable Management	22
5.3.2. Rack Cable Management.....	23
5.3.2.1. <i>TAK-TY</i> ® Hook & Loop Cable Tie.....	23
5.3.4. Wall or Backboard Mounted Cable Management	23
5.3.4.1. D – Rings (Metallic) (To be expanded on in Q2 2010).....	23
5.3.5. Ladder Rack Accessories	23
5.3.5.1. Waterfall Accessories	23
5.3.5.2. Threaded Rod Cover.....	24
5.3.5.3. Stackable Cable Rack Spacers.....	24
5.3.6. Cable Support System Accessories	24
5.3.7. Cable Support System	25
5.3.8. Fiber Routing Systems	26
5.3.9. Rack Equipment	26
6. Backbone Cabling System	28
6.1 Voice Backbone.....	28
Voice Cable	28
6.1.1.1. Multi-pair Category 5e UTP Cable	28
Voice Termination and Cross-connects	28
6.1.1.2. Modular Patch Panels and Cords.....	29
6.2. Data Backbone	29
Data Cable	29
Data Termination and Cross Connects.....	29
6.2.1. Fiber Connectors and Patch Cords	29
7. Identification.....	31
7.1. Patch Panels and Communications Outlets	31
8. Testing Data.....	32
<u>Approved Test Leads For PANDUIT Mini-Com® TX6™</u>	32
Permanent Link	32
Channel.....	33
<u>Accepted Test Leads For PANDUIT Mini-Com® TX6™</u>	34
Permanent Link	34
9. Appendixes:.....	35
9.1. Appendix 7	35

1. Introduction

1.1. Purpose

The purpose of this document is to provide documentation to cabling professionals interested in providing Florida State College at Jacksonville commercial building structured cabling.

The documentation includes:

- Product specifications
- Minimum product performance
- Structured cabling design considerations
- Installation guidelines

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

The information contained in this document is based on our experience to date and is believed to be reliable. It is intended as a guide for use by persons having technical skill and is to be used with their own discretion and risk. Dimensions contained herein are for reference purposes only. For specific dimensional requirements consult the factory.

1.2. Applicable Standards

The following industry standards are the basis for the structured cabling system described in this document. The list is incorporated by this reference to them.

TIA/EIA

- TIA/EIA-568-B Commercial Building Telecommunications Cabling Standard
- TIA/EIA-568-B.1 General Requirements
- TIA/EIA-568-B.2 Balanced Twisted Pair Cabling Components Standard
- TIA/EIA-568-B.2-1 Transmission performance for 4 pair 100 Ω category 6
- TIA/EIA-568-B.3 Optical Fiber Cabling Components Standard
- TIA/EIA-569-A Commercial Building Standard for Telecom Pathways and Spaces
- TIA/EIA-606 Administration Standard for the Telecommunications Infrastructure of Commercial Buildings
- TIA/EIA-607 Commercial Building Grounding/Bonding Requirements

NFPA

- NFPA-70 National Electric Code (NEC)-2002

ISO/IEC

- ISO/IEC 11801 Generic Cabling for Customer Premises

The most recent versions of all documents apply to this project. If there is a conflict between applicable documents, the order above shall dictate the order of precedence in resolving the issue unless an enforceable local or national code is in effect.

1.3. Additional Support

1.3.1. PanGen™ System Warranty

A PanGen™ System Warranty shall provide a complete system warranty to guarantee end-to-end high performance cabling systems that meet application requirements. The guarantee shall include cable and connectivity components and have one point of contact for all cabling system issues. The system shall be warranted for a period of at least 25 years.

1.3.2. Contractor Agreement

In order for the structured cabling system or additional links to be eligible for warranty coverage, an installation company trained and certified by **BICSI**, **PANDUIT**® and **General Cable** must install them. The contractor shall have completed standards based product and installation training. ***A copy of the BICSI Certificate, PCI Certificate or PanGen Installer Certificate shall be submitted in the proposal.***

FLORIDA STATE COLLEGE AT JACKSONVILLE INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

2. Telecommunication Network System Requirements

2.1. Description

The Structured Cabling System shall consist of any one or all of the following structured cabling elements or subsystems:

- Work area
- Horizontal cabling
- Telecommunications room (or horizontal cross connect)
- Backbone cabling
- Equipment room
- Entrance facility
- All cable support structure

2.2. Supported Applications

The Structured Cabling System shall be capable of supporting and/or integrating the following:

- Analogue and digital voice applications
- Data applications
- Local area network services
- Wide area network services
- Video services
- Low voltage devices for building controls

The applications that shall be supported include, but are not limited to:

- Data Communications
 - Token Ring (IEEE 802.5)
 - Ethernet (10 Base-T, 100 Base-T, 1000 Base-T)
 - 100 Base VG Any LAN
 - ATM (155 Mbps, 622 Mbps)
 - Fiber Distributed Data Interface (FDDI)
 - Twisted Pair-Physical Medium Dependant (TP-PMD)
 - IBM System 3X
 - IBM AS/400
 - AppleTalk
 - Arcnet
 - ISDN
 - CDDI
 - Any other application designed to run on a generic structured cabling system designed and installed to TIA or ISO structured cabling standards
- Data Processing
 - Mainframe access client server, enterprise server, messaging systems and electronic mail, client database, etc
- Voice Applications
 - Digital and analog PBXs and key systems
- Video
 - Analogue video, digital video, and video conferencing
- Building Services

FLORIDA STATE COLLEGE AT JACKSONVILLE INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

- Heating, ventilation, and air conditioning (HVAC) monitoring and control
- Lighting monitoring and control
- Motion sensors
- Public address and paging systems
- Security
- Access Control Systems
- Other low voltage devices
- Multiple Services
 - The structured cabling system shall also support backward and forward migration of applications with minimal disruption to existing services or personnel, allowing for quick moves, adds, and changes

2.3. Additional Requirements

- Categorized copper product shall be used in conjunction with *General Cable* of equivalent or higher Category cable as verified by ETL, UL or *PANDUIT*[®] engineering
- All structured cabling products shall be installed according to any applicable instructions
- All networks and other applications shall be installed per applicable standards and manufacturers' guidelines and transmitted over the appropriate minimum Category copper cable or fiber cable for which it was intended to operate on
- All applicable local, state, national, and federal electrical and fire safety standards shall be adhered to during and after installation

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

3. Work Area Subsystem

The Work Area shall consist of the connectivity equipment used to connect the horizontal cabling subsystem and the equipment in the work area. Both copper and fiber media shall be supported. The connectivity equipment shall include the following options:

- Patch (equipment) cords and modular connectors
- Outlets and surface mount boxes
- Surface raceway and outlet poles

3.1. Patch Cords and Modular Connectors

The modular connectors and patch cords will be chosen to match the horizontal cabling medium and rating. The same manufacturer shall provide the modular connectors and patch cords. The total patch cord length at the work area is not to exceed three meters (10 ft). Exception: When implementing an open office cabling system as specified under TIA/EIA 568-B (see section 3.4).

3.1.1. Copper

The *PANDUIT*[®] *MINI-COM*[®] Network Cabling System or AVP of Computing Infrastructure approved equivalent shall be used for the Work Area subsystem, including all modular connectors. The network cabling system shall be comprised of modular connectors in support of high-speed networks and applications designed for implementation on copper cabling. All outlets shall utilize fully interchangeable and individual connector modules that mount side-by-side to facilitate quick and easy moves, adds and changes.

3.1.1.1. Category 6 UTP

MINI-COM[®] *TX6*[™] Plus Jack Modules shall be Category 6 modules featuring eight positions that shall be used in all work areas and shall exceed the connector requirements of the TIA/EIA Category 6 standard. Jack module shall use forward motion termination to optimize performance by maintaining cable pair geometry and eliminating conductor untwist. The termination cap shall provide strain relief on the cable jacket, ensure cable twists are maintained to within 1/8” (3.18mm) and include a wiring scheme label. The wiring scheme label shall be available with both T568A and T568B wiring schemes. All terminations shall use the T568B (B) wiring scheme. The modules shall terminate four pair 22 - 26 AWG 100 ohm solid unshielded twisted pair cable. The modules shall be universal in design, including complying with the intermatability standard IEC 60603-7 for backward compatibility. Category 6 modules shall have UL and CSA approval. The modules shall have ETL verified Category 6 performance and ISO Class E performance (as defined in ISO/IEC 11801) in both the basic and channel links. They shall be universal in design, accepting six or eight pair modular plugs without damage to the outer module contacts. The modules shall be able to be re-terminated a minimum of 10 times and be available in 11 standard colors for color-coding purposes with the preferred color being **blue (CJ688TGBU)**. The module shall snap into all *MINI-COM*[®] outlets and patch panels. The module shall include an ivory colored base to signify Category 6 330 MHz performance.

Part Number	Style	Category	Colors
CJ688TG**	RJ45	6	11

** Designates color

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

PanGen™ Category 6 Patch Cords shall be factory terminated with modular plugs featuring a tangle-free latch design and clear strain-relief boots to support easy moves, adds and changes. Each patch cord shall be 100% performance tested at the factory to the TIA/EIA Category 6 standard. The patch cords shall come in standard lengths of three, five, seven, 10, and 14 feet and six standard colors of Blue, Green, and Red. Red (**=RD) shall be used for Enterprise equipment, Blue (**=BU) shall be used for Staff Connections, and Green (**=GR) shall be used for Student Connections.

Part Number	Length (ft)	Length (M)
UTPSP3**Y	3	0.91
UTPSP5**Y	5	1.52
UTPSP7**Y	7	2.13
UTPSP10**Y	10	3.04
UTPSP14**Y	14	4.27

** Designates color

3.1.1.2. Additional Copper Cabling Connectors

Additional *MINI-COM*® Modules for copper shall include the following:

- 50 and 75 Ohm BNC coax coupler modules, male-male
- F-Type coax coupler module, male-male threaded
- RCA connector modules with black, red, yellow, and white inserts
Solder pass through and punchdown termination types
- S-Video connectors modules - coupler and punchdown termination types
- Blank module to reserve space for future additions

The connectors shall snap into all *MINI-COM*® outlets and patch panels.

Part Number	Style	Medium	Termination Style	Colors
CMBA**	BNC	Coax	Coupler	5
CMBA75**	BNC	Coax	Coupler	5
CMFBA**	F-Type	Copper	Coupler	5
CMFSR**	F-Type	Copper	Coupler	5
CJRR**	RCA - red	Copper	Punchdown	5
CJRY**	RCA - yellow	Copper	Punchdown	5
CJRW**	RCA - white	Copper	Punchdown	5
CMRPR**	RCA - red	Copper	Pass through	5
CMRPY**	RCA - yellow	Copper	Pass through	5
CMRPW**	RCA - white	Copper	Pass through	5
CMSVC**	S-Video	Copper	Pass through	5
CJSV**	S-Video	Copper	Punchdown	5
CMB**	Blank	-	-	5

** Designates color

3.1.2. Fiber Optic

The *PANDUIT*® *MINI-COM*® network cabling system or *AVP of Computing Infrastructure approved equivalent* shall be comprised of *PANDUIT*® Fiber Optic modular connectors in support of high-speed networks and applications designed for implementation on multimode (50/125µm) glass fiber cabling.

All outlets shall utilize interchangeable and individual connector modules that mount side by side to facilitate quick and easy moves, adds, and changes. Approved components of

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

the Fiber Termination Hardware for the Work Area Subsystem shall include but are not limited to:

LC small form factor (SFF) fiber optic adapters with integrated panel retention clips are TIA/EIA-604 FOCIS-10 compatible. Each LC simplex adapter shall connect one LC connector pair in one module space. Each LC duplex adapter shall connect two LC connector pairs in one module space. LC adapters and adapter modules shall include phosphor bronze split sleeves for multimode applications or zirconia ceramic split sleeves for singlemode applications.

Standards requirements: TIA/EIA-604 FOCIS-10 compatible; exceeds TIA/EIA-568-B.3 requirements

Split sleeve material: Phosphor bronze or zirconia ceramic (required for singlemode applications)

Insertion loss: .1dB average (multimode and singlemode); supports the performance of FOCIS-10 compliant connectors/patch cords

Return loss: Supports singlemode (>40dB for SPC and >55dB for UPC) and multimode (>20dB) connector polish performance

Part Number	Description
FADSLCEI-L	LC Sr/Sr. Dupl Fiber Optic Adapter EI (Phos)

3.2. Outlets and Surface Mount Boxes

The outlets and surface mount boxes shall support the network system by providing high-density in-wall, surface mount or modular office furniture cabling applications. The outlets consist of faceplates for flush and recessed in-wall mounting as well as mounting to the modular office furniture systems. The surface mount boxes can be mounted where in-wall applications are not possible or to support applications where surface mount is the best option.

All outlets shall utilize fully the interchangeable and individual *MINI-COM*[®] connector modules that mount side by side to facilitate quick and easy moves, adds and changes. All outlets shall be manufactured from high-impact thermoplastic material with a U.L. flammability rating of 94 HB or better. All outlets and surface mount boxes shall be available in four colors including Off White (IW), Electrical Ivory (EI), White (WH) and International Gray (IG).

Faceplates

MINI-COM[®] Executive Series Faceplates shall be one, two, four and six port vertical single gang and 10 port vertical double gang faceplates with combination head screws, screw covers, labels, label covers and a curved, designer appearance. The faceplates shall mount to standard U.S. NEMA boxes and adapters with screw-to-screw dimensions of 3.28" (83.3mm). The insert labels shall meet UL 969. Each faceplate shall accept *MINI-COM*[®] modules that can be individually inserted and removed as required.

Part Number	Gang	Number of Modules
CFPE1**	Single	1
CFPE2**	Single	2
CFPE4**	Single	4
CFPE6**	Single	6
CFPE10**-2G	Double	10

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

** Designates color

Modular Furniture Faceplates

MINI-COM[®] Modular Furniture Faceplates shall be four-port flat or angled and two port angled faceplates that snap directly into TIA/EIA standard furniture openings. The two port, angled faceplate shall provide a 45° slope to the side, in-line with the cable running through the furniture channel. If required, an extender shall be used with the four port flat faceplate to provide 12.7mm (0.5") additional depth. Each faceplate shall accept *MINI-COM*[®] modules that can be individually inserted and removed as required.

Part Number	Number of Modules	Orientation
CFFP4**	4	Flat
CFFPA2**	2	Sloped
CFFPL4**	4	Flat with Label
CFFPLA4**	4	Sloped with Label

** Designates color

Faceplate Frames and Inserts

MINI-COM[®] Executive Series Faceplate Frames shall be vertical, single and double gang frames with combination head screws, screw covers, labels, and a curved designer appearance. The faceplates shall mount onto standard U.S. NEMA boxes and adapters with screw-to-screw dimensions of 3.28" (83.3mm). Each faceplate frame shall accept flat, sloped, sloped shuttered, sloped recessed and blank 1/2 and 1/3 size module inserts that can be individually inserted and removed as required from the front of the frame without removing the frame.

Part Number	Gang	Number of Modules
CBE**	Single	Up to 6
CBE**-2G	Double	Up to 12

** Designates color

Stainless Steel Faceplates

MINI-COM[®] Stainless Steel Faceplates shall be two, four and six-port vertical single gang and four, eight and 10 port double gang faceplates with combination head stainless steel screws. The faceplates shall mount to standard U.S. NEMA boxes and adapters with screw-to-screw dimensions of 3.28" (83.3mm). Faceplates shall be flush mounted for clean look. Stainless steel material shall be riveted to high impact ABS backing to provide a durable faceplate with brush finish. Each faceplate shall accept individual copper and fiber optic connector modules that can be individually inserted and removed as required.

Part Number	Gang	Finish	Number of Modules
CFP2S	Single	Stainless steel	2
CFP4S	Single	Stainless steel	4
CFP6S	Single	Stainless steel	6
CFP4S-2G	Double	Stainless steel	4
CFP8S-2G	Double	Stainless steel	8
CFP10S-2G	Double	Stainless steel	10

Surface Mount Boxes

MINI-COM[®] Low Profile Surface Mount Boxes shall be one, two, four, six and 12-port low profile surface mount boxes with a 28mm (1.1") maximum height. All connections (with exception of the 12 port low profile box) shall exit one side of the box, parallel to

FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

the wall. The boxes shall be capable of mounting with screws, adhesive, and/or magnets. The two port boxes shall include a removable blank for addition of a second port. The four, six and 12 port boxes shall include breakouts for use with *PAN-WAY*[®] surface raceway and cable tie slots at each raceway entry point to provide strain relief on incoming cables. The four (except low profile four), six, and 12 port boxes shall include tamper resistant screws that securely fasten the cover to the base and are concealed by screw covers and labels. Each box shall accept individual *MINI-COM*[®] modules that can be individually inserted and removed as required.

Part Number	Number of Modules	Maximum Height
CBX1**-A	1	23mm
CBXJ2**-A	2	23mm
CBX2**-A	2	27mm
CBXC4**-A	4	23mm
CBX4**-A	4	28mm
CBXD6**-A	6	26mm
CBX12**-A	12	26mm

** Designates color

MINI-COM[®] Fiber/Multi-Media Surface Mount Boxes shall be six and 12-port surface mount boxes with all connections exiting one side of the box, parallel to the wall. The six and 12 port boxes shall contain a “captive” fiber spool that maintains a minimum 25.4mm (1”) bend radius. The six and 12 port boxes shall store up to 24 meters of buffered optical fiber. The boxes shall be capable of mounting with screws, adhesive, and/or magnets. The boxes shall include breakouts for use with *PAN-WAY*[®] surface raceway on three sides and cable tie slots at each raceway entry point to provide strain relief on incoming cables. The boxes shall include tamper resistant screws that securely fasten the cover to the base and are concealed by screw covers and labels. Each box shall accept *MINI-COM*[®] modules that can be individually inserted and removed as required.

Part Number	Number of Modules	Maximum Height
CBXF6**-A	6	25mm
CBXF12**-A	12	46mm

** Designates color

Other Outlet Components

MINI-COM[®] “106” Frames shall be a two or four port frame that mounts onto U.S. NEMA standard junction boxes and wall board adapters with screw-to-screw dimensions of 3.28” (83.3mm) and behind NEMA standard “106” duplex electrical faceplates. Frame shall accept individual modules that can be individually inserted and removed as required.

MINI-COM[®] “GFCI” Frames shall be one, two, and four port frames that mount to wallboard adapters and behind NEMA standard “GFCI” electrical faceplates. Each frame shall accept individual connector modules that can be individually inserted and removed as required.

Part Number	Number of Modules	Frame Type
CFG1**	1	GFCI
CFG2**	2	GFCI
CFG4**	4	GFCI
CF1062**	2	106 Duplex
CF1064**	4	106 Duplex

** Designates color

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

3.3. Surface Raceway and Vertical Outlet Pole

Surface raceway and vertical outlet poles refers to a surface raceway system used for branch circuit wiring and/or data network, voice, video and other low-voltage cabling. Surface raceway shall be used in solid wall applications or for applications where moves, adds and changes are very typical to the workflow. The raceway system shall consist of raceway, appropriate fittings and accessories to complete installation per electrical and/or data drawings.

Non-metallic surface raceway is to be utilized in dry interior locations only as covered in Article 388 of the NEC, as adopted by the NFPA and as approved by the ANSI.

3.3.1. Multi-Channel (Coming Soon)

3.3.2. Single Channel (Coming Soon)

3.3.3. Outlet Pole

Outlet Poles refers to dual channel, floor-to-ceiling pole that provides convenient access to power and communication outlets. The Outlet Pole provides a floor space efficient and MAC friendly solution to power and communication access in open office, education, retail, factory, or warehouse applications. The outlet poles shall be available in 11' or 13' lengths.

Power and Communication Channels

The Power and Communications Pole channel shall be aluminum, in either off-white or electrical ivory color, with a cross sectional area of 2.90" X 1.77" with two separate compartments. One compartment is to be factory wired with two, (2) duplex style 20A, 125V NEMA 5-20R grounding-type specification grade receptacles, and colored, to match the pole finish.

Receptacles must be UL tested to meet the performance requirements of Fed. Spec. W-C695G General Specification for Electrical Power Connectors and conform to NEMA specification WD 1-7.01 to 7.10 "Heavy Duty General Use Grounding Receptacle". Receptacles shall also be UL Listed and be in compliance with UL-498.

The harness is to be single circuit (2 conductor plus ground) with #12 AWG solid type THHN conductors, factory assembled to the receptacles.

Six-inch (6") conductor leads are to be furnished for termination to the overhead wiring system. A power entry box with ½, and ¾ " conduit breakouts, and 8" removable plate must be provided at the top of the power compartment to facilitate the hard wiring of the pole harness.

The second compartment is to be for field installation of telephone or data network cabling. A nonmetallic cover, which is removable and easily cut to create an opening for installation of communications faceplates, shall be provided to enclose the channel. The channel shall accept Snap-On communication faceplates or a standard faceplate bracket capable of mounting a NEMA standard single-gang communications faceplate. The channel shall be capable of mounting up to six communication faceplates, providing up to 24 communication ports.

Communication Only Channel

The Communications Only Pole shall be aluminum, in either off-white or electrical ivory color, with a cross sectional area of 2.90" x 1.77" with one compartment.

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

The compartment is to be for field installation of telephone or data network cabling. A nonmetallic cover that is removable and easily cut to create an opening for installation of communications faceplates shall be provided to enclose the channel. The channel shall accept Snap-On communication faceplates or a standard faceplate bracket capable of mounting a NEMA standard single-gang communications faceplate. The channel shall be capable of mounting up to six communication faceplates, providing up to 24 communication ports.

Mounting Hardware and Fittings

A full compliment of mounting hardware and fittings for the Power and Communications Pole and Communications Only Pole shall be provided. These shall include, but are not limited to, entrance end fitting, which protects cable bend radius, for the top of the pole, ceiling trim plate, pole mounting bracket, Velcro carpet gripper pad, and adhesive pad.

Pan-Pole Outlet Pole Extensions Kits

Two extension kits will be made available to construct outlet poles of 16' and 22'. Both kits consist of a pre-wired *PAN-POLE*™ and coupler, which attach to one of the standard 11' or 13' poles. Both of these kits maintain the dual channel aluminum construction that provides the complete separation of power and data.

Field Modification of Power and Communications Pole

The power and communications pole must be UL listed for field modifications, changes and additions of receptacles, devices, and circuits. Field installed power device addition kits shall be available to add duplex receptacles and shall be provided with plates that are color matched to the appropriate power and communications pole.

Snap-On Communication Faceplates

Snap-On single-gang communication faceplates must be available to mount workstation device faceplates, inserts and specialty mounting bezels. The power pole manufacturer will provide a complete line of connectivity outlets and modular inserts for UTP (including Categories 5, 5e and 6*), STP (150 ohm), Fiber Optic, Coaxial, and other cabling types. The workstation inserts shall also have available a complete line of port and station identification labels in a variety of colors that meet the requirements for ANSI/EIA/TIA 606.

Part Number	Description	Size
PCPA11R20**	Power & Communications Pole	11' L
PCPA13R20**	Power & Communications Pole	13' L
PCPA11**	Communications Pole	11' L
PCPA13**	Communications Pole	13' L
PCPAKR20**	Power Addition Kit with 20A Duplex Receptacle	
PCPAKR**	Power Addition Kit without receptacle	
PCPAK16**	Power Pole Extension Kit	-
PCPAK22**	Power Pole Extension Kit	-
T70SDB-X	Standard Faceplate Mounting Bracket (for Communication)	

** Designates color option

4. Horizontal Cabling Subsystem

The horizontal cabling system is the portion of the telecommunications cabling system that extends from the work area telecommunications outlet/connector to the horizontal cross-connect in the TC.

- Horizontal cabling in an office should terminate in a TC located on the same

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

- floor as the work area being served
- Horizontal cabling is installed in a star topology (home run)
- Bridged taps and splices are not permitted as part of the copper horizontal cabling
- *Rooms are to be arranged in sequential order on the patch panels.*

4.1. Copper UTP Cable

Recommended design shall include:

- Minimum one Four-pair 100 ohm, 23 AWG, GenSPEED 6000E– UTP Enhanced Category 6 Cable
- Maximum cable length is 90 meter
- All cable shall meet or exceed the following specifications

Category 6 UTP Cable

GenSPEED 6000E– UTP Enhanced Category 6 Cable CMR and CMP rated cables that will meet or exceed the requirements of ANSI/TIA/EIA Category 6e Cabling.

These requirements are for cables of unshielded 23 AWG bare copper conductors, insulated with thermoplastic, twisted into pairs and enclosed in a thermoplastic jacket. The finished cable shall meet or exceed the following requirements of ANSI/EIA/TIA 568-B-2.1.

All cable shall conform to the requirements for communications circuits defined by the National Electrical Code (Article 800) and the Canadian Building Code. Cable listed to NEC Article 800-51(a) will be used for “Plenum” installations and carry labeling of CMP. Cable listed to NEC Article 800-51(b) shall be installed in vertical runs penetrating more than one floor and carry the labeling of CMR.

The cable manufacturer shall be ISO 9001/TL 9000 registered.

Physical Characteristics

- Conductor shall be 23 AWG solid bare annealed copper.
- The jacket shall be printed with TRU-Mark™ 1000' to 0' marking system.
- Shall be suitable for use indoor, riser, or plenum and horizontal applications.
- Category marking shall be printed every one foot.
- Shall be independently verified to comply with TIA/EIA 568B.2-1 and TIA568C Draft
- Shall be packaged in a way protecting the cable.

**FLORIDA STATE COLLEGE AT JACKSONVILLE
 INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

- Temperature range on cable shall be 0 to +60C for
- Installation and -20 to +75C for Operation.

Transmission Characteristics

- Cable shall be ANSI/TIA/EIA-568-B.2-1 & Draft 568-C and ISO/IEC 11801 category 6 compliant.
- Attenuation shall be measured in accordance with TIA/EIA 568B.2-1 & Draft 568-C and shall be a maximum of 19.7dB @ 100 MHz.
- Cable shall exhibit positive PSACR of at least 8.7dB at or above 250 MHz.
- Cable shall be tested & characterized to 500 MHz.
- Cable shall be UL LISTED and RoHS Compliant.
- An ISO 9001 Certified facility shall manufacture Cable.

Cable shall exhibit a NEXT loss of at least the following:

Frequency MHz	NEXT dB
1.0	79.3
4.0	70.3
10.0	64.3
16.0	61.3
20.0	59.8
31.25	56.9
62.5	52.4
100.0	49.3
200	44.8
250	43.3
350	41.2
500	38.8

Cable shall exhibit ELFEXT loss of at least the following:

Frequency MHz	ELFEXT dB
1.0	72.8
4.0	60.7

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

10.0	52.8
16.0	48.7
20.0	46.7
31.25	42.9
62.5	36.8
100.0	32.8
200	26.8
250	24.8
350	21.9
500	18.8

Cable shall exhibit Attenuation loss of less than the following:

Frequency MHz	Attenuation dB
1.0	2.0
4.0	3.8
10.0	5.9
16.0	7.5
20.0	8.4
31.25	10.7
62.5	15.4
100.0	19.8
200	29.0
250	32.6
350	39.5
500	48.6

Cable shall exhibit a return loss according to the following:

Frequency MHz	Return Loss (dB)
1	20.0
4	23.6
10	26.0
16	26.0
20	26.0
31.25	25.0
62.5	23.5
100	22.5
200	21.0
250	20.5
350	19.8
500	19.0

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

Approved Manufacture:

General Cable GenSPEED 6000E

CMP: 7131900 or 7133940

4.2. Fiber Cable

Horizontal Distances - Optical Fiber Links

When using optical fiber cables, any length of horizontal cables, work area cables, patch cords, and equipment cables is acceptable so long as the total of the combined lengths does not exceed manufacturers recommended distance outlined below per application.

Transmission is typically at 850 or 1300 nm for 50/125µm multimode optical fiber and at 1310 and 1550 nm for Single-mode.

Specifications

ANSI/TIA/EIA-568-B.3 Horizontal fiber cable distribution systems:

- The optical fiber cable shall consist of a minimum of two 50/125µm or 8.3/125µm optical fibers enclosed by a protective sheath
- The cable will be capable of supporting 1 gig and 10 gig applications
- The optical fiber shall be 50/125µm multimode or 8.3/125µm single-mode
- The mechanical and environmental specification for the optical fiber cable will be in accordance with ANSI/ICEA-S-83-596.

Performance

50/125µm optical fiber

Fiber Type	Wavelength (nm)	Maximum Attenuation (dB/km)	10 Gigabit Ethernet Link Length (meters)	1 Gigabit Ethernet Link Length (meters)
BL	850	3.0 (Typical 2.8)	550	1000
	1300	1.0 (Typical 0.8)		600
BE	850	3.0 (Typical 2.8)	300	1000
	1300	1.0 (Typical 0.8)		600
BI	850	3.0 (Typical 2.8)	150	750
	1300	1.0 (Typical 0.8)		600

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

Single-Mode optical fiber

Fiber Type	Wavelength (nm)	Typical Attenuation (dB/km)	10 Gigabit Ethernet Link Length (meters)	1 Gigabit Ethernet Link Length (meters)
AP	1310	0.65	5000	10000
	1550	0.65	30000	

Approved Manufacture:
General Cable NEXTGEN brand

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

5. Telecommunications Room

The telecommunications room (TR) includes those products that connect the networking equipment to the horizontal and backbone cabling subsystems. These products include termination hardware (connectors and patch cords), racks, cable management products and cable routing products.

5.1. Cable Termination Hardware

Each horizontal or backbone cabling run will be terminated using appropriate connectors or connecting blocks depending upon the cable type. Matching patch cords will be used to perform cross-connect activities or to connect into the networking/voice hardware.

5.1.1. Category 6 Unshielded Twisted Pair UTP

Four-pair Category 6 cabling shall be terminated onto modular patch panels.

5.1.1.1. Modular Patch Panels and Cords

Four-pair Category 6 UTP cabling shall be terminated onto a four-pair Category 6 module. All modules shall be terminated using the T568B wiring scheme. The eight-position module shall exceed the connector requirements of the TIA/EIA Category 6 standard. The module termination to four-pair, 100 ohm solid unshielded twisted pair cable shall be accomplished by use of a forward motion termination cap and shall not require the use of a punch down or insertion tool.

Angled Filler Panels

Part Number	Flat/Angled	Number of Ports	Rack Spaces
CPAF1BL	A	N/A	1
CPAF2BL	A	N/A	2

MINI-COM® Flush Mount Modular Patch Panels shall be of metal design with rear-mounted faceplates allowing modules to be flush with the front of the patch panel. There shall be pre-printed numbers above each port for easy identification and white write on areas for port and/or panel identification on the 24 and 48 port version. Panels shall be the angled versions. Angled panels facilitate proper bend radius control and minimize the need to horizontal cable managers.

Part Number	Flat/Angled	Number of Ports	High Density	Number of Rack Spaces
CPPA48FMWBL	A	48		2

PanGen™ Category 6 Patch Cords shall be factory terminated with modular plugs featuring a tangle-free latch design and clear strain-relief boots to support easy moves, adds and changes. Each patch cord shall be 100% performance tested at the factory in a channel test to the TIA/EIA Category 6 standard. The patch cords shall come in standard lengths of three, five, and seven feet and six standard colors of Off White, Black, Blue, Green, Red and Yellow with the

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

preferred color being Blue (**=BU). Only three, five and seven foot cords are to be used in the TR's.

Part Number	Length (ft)	Length (M)
UTPSP3**	3	0.91
UTPSP5**	5	1.52
UTPSP7**	7	2.13
UTPSP10**	9	3.04

** Designates color

Fiber Termination Hardware

5.1.1.2. Fiber Optic Connectors and Patch Cords

MINI-COM[®] LC[®] Duplex Jack Modules and Plugs

Fiber optic connectors

LC small form factor (SFF) field polish connectors with rear pivot latch shall be TIA/EIA-604 FOCIS-10 compatible. LC simplex and duplex connectors shall be field terminable. The fibers shall terminate in 1.25mm ceramic ferrules with non-optical disconnect functionality and an average insertion loss of 0.1dB per mated pair for multimode and singlemode fiber.

Standards requirements: TIA/EIA-604 FOCIS-10 compatible; exceeds TIA/EIA-568-B.3 requirements

Split sleeve material: Phosphor bronze or zirconia ceramic (required for singlemode applications)

Insertion loss: .1dB average (multimode and singlemode); supports the performance of FOCIS-10 compliant connectors/patch cords

Return loss: Supports singlemode (>40dB for SPC and >55dB for UPC) and multimode (>20dB) connector polish performance

Part Number	Description
FLCDM900EIY	LC mm Dupl Connector With 900µm Boots - Field Polish
FLCDMEIY	LC Dupl Multimode Fiber Optic Connector - Field Polish
FLCDSBUY	LC Dupl Singlemode Fiber Optic Connector - Field Polish
FLCSMEIY	LC Simpl Multimode Fiber Optic Connector - Field Polish

Part Number				
FLCSMEIY	Simplex	900µm buffered fiber and 1.6mm – 2.0mm jacketed cable	Multimode	Zirconia Ceramic
FLCSM3.0EI	Simplex	3.0mm jacketed cable		
FLCDMEIY	Duplex	1.6mm – 2.0mm jacketed cable		
FLCDM900EIY	Duplex	900µm buffered fiber		
FLCDM3.0EI	Duplex	3.0mm jacketed cable		
FLCSSBUY	Simplex	900µm buffered fiber and 1.6mm – 2.0mm jacketed cable	Singlemode	Zirconia Ceramic
FLCSS3.0BU	Simplex	3.0mm jacketed cable		
FLCDSBUY	Duplex	1.6mm – 2.0mm jacketed cable		
FLCDS900BUY	Duplex	900µm buffered fiber		
FLCDS3.0BU	Duplex	3.0mm jacketed cable		

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

5.2. Fiber Optic Equipment

Enclosures

OPTICOM™ Wall mounted fiber optic enclosures shall be constructed of steel material. Enclosures shall provide patch cable protection without the installation of an additional attachment. Enclosures shall maintain discrete locking capability between installer and end user segments.

Part Number	Number of Fibers
FWME2	48 duplex LC
FWME4	96 duplex LC
FWME8	192 duplex LC
FMP6	Blank Panel accepts up to 6 <i>MINI-COM</i> ® Adapters
FAP6WEIDL	Fiber Optic Adapter Panel - (6) LC Duplex Multimode
FAP6WBUDLCZ	Fiber Optic Adapter Panel - (6) LC Duplex Single mode
FAP8WEIDL	Fiber Optic Adapter Panel - (8) LC Duplex Multimode
FAP8WBUDLCZ	Fiber Optic Adapter Panel - (8) LC Duplex Single mode
FAP12WEIDL	Fiber Optic Adapter Panel - (12) LC Duplex Multimode
FAP12WBUDLCZ	Fiber Optic Adapter Panel - (12) LC Duplex Single mode

OPTICOM™ Rack mounted fiber optic enclosures shall be designed to manage and organize fiber optic cable to and from the equipment or cabling plant. Enclosures shall protect fiber optic connections for patching or splicing requirements. Enclosures shall accommodate up to 36 fibers (with Fiber Jack LC) per rack space and shall be constructed of steel material. Enclosures shall have removable front and rear covers and top and bottom pass through holes.

Part Number	Rack Spaces	Number of Fibers
FRME1	1	72 duplex LC
FRME2	2	144 duplex LC
FRME3	3	216 duplex LC
FRME4	4	288 duplex LC

5.3. Cable Management

The Cable Management System shall be used to provide a neat and efficient means for routing and protecting fiber and copper cables and patch cords on telecommunication racks and enclosures. The system shall be a complete cable management system comprised of vertical cable managers, horizontal cable manager, and cable management accessories used throughout the cabling system. The system shall protect network investment by maintaining system performance, controlling cable bend radius and providing cable strain relief.

5.3.1. Vertical Cable Management

Vertical cable managers shall include components that aid in routing, managing and organizing cable to and from patch panels and/or equipment. Managers shall protect network equipment by controlling cable bend radius and providing cable strain relief. Managers shall be a universal design mounting to EIA 19" or 23" racks and constructed of a base with cable management fingers.

The fingers shall include retaining tabs to keep cables in place during cover removal. The covers shall be hinged to open in either direction allowing for quick moves, adds, and changes.

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

Part Number	Type	Rack Spaces	Type	Max. Side Extension (in.)
PRV12	Front and Rear	45	High Capacity	12.0
PRD12	Hinged Door	-	-	12.0
PRV10	Front and Rear	45	High Capacity	10.0
PRD10	Hinged Door	-	-	10.0
PRV8	Front and Rear	45	Standard	8.0
PRD8	Hinged Door	-	-	8.0
PREP	End Panel	-	-	-
PRSP5	Rear Slack Spool, 5"	-	-	-
PRSP7	Front Slack Spool, 7"	-	-	-

5.3.2. Rack Cable Management

5.3.2.1. TAK-TY® Hook & Loop Cable Tie

A 3/4" maximum *TAK-TY*® Cable Ties or *AVP of Computing Infrastructure approved equivalent* is to be used to secure bundles of communication cabling in cabinets, closets or other environments where cable management is a concern.

* Flame retardant products are manufactured from a material that is rated UL94V-0.

5.3.3. Strain Relief Bars

Strain relief bars are used to support and manage cables in telecommunications rooms. They provide strain relief, bend radius control, superior aesthetics and improve organization and routing of cable. Strain relief bars can be used with 19" rack mountable *MINI-COM*™ Modular and Data Patch Panels. Each strain relief bar occupies one-third to two-thirds of a rack space and can secure and manage up to 24 cables in 1 RU. *PANDUIT* offers a full line of strain relief bars to fit a variety of applications offering end users flexibility and convenience to prevent cable strain. Higher density applications may be addressed with *PANDUIT* strain relief bar manager (SRBM19BLY).

Part Number	Description	Color
SRB19BLY	Strain Relief Bar	Black

5.3.4. Wall or Backboard Mounted Cable Management

5.3.4.1. D – Rings (Metallic) (To be expanded on in Q2 2010)

5.3.5. Ladder Rack Accessories

5.3.5.1. Waterfall Accessories

Cable Management Waterfall Accessories shall be utilized to transfer communication cable from ladder racks to enclosures or equipment racks below. These cable management waterfall systems shall maintain 1" bend radius control in both vertical and horizontal directions. The system shall be modular in order to allow for multiple widths.

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

Part Number	Description	Color
CMW-KIT	Waterfall Kit	Black
CMWB	Waterfall Base	Black
CMWW	Waterfall Wing	Black

5.3.5.2. Threaded Rod Cover

The Threaded Rod Cover or AVP of Computing Infrastructure approved equivalent shall be utilized to protect communication cable from abrasion caused by contact with threaded rod. The Threaded Rod Cover shall be manufactured from a gray flame-retardant polyethylene material that is UL94V-0 rated. The material shall be pliable to allow for easy installation.

Part Number	For Threaded Rod Size	Length
TRC18FR-X8	1/2" to 5/8"	18"

5.3.5.3. Stackable Cable Rack Spacers

Stackable Cable Rack Spacers shall be utilized to route bulk fiber optic cable or high performance copper communication cable bundles. Stackable Cable Rack Spacers shall be utilized in communication closets and other interior locations where cables and cable bundles are routed along traditional ladder racks that consist of rungs and stringers. The Stackable Cable Rack Spacers shall be applied on every other rung up to a recommended maximum stack height. Dovetail slots and a positive latching mechanism shall provide a secure locking feature.

Part Number	Cable Bundles	Bundle Diameter	Recommended Stack Height
CRS6-X	6	.8"	5
CRS1-X	1	.8"	5
CRS4-125-X	4	1.25"	4
CRS1-125-X	1	1.25"	4

5.3.6. Cable Support System Accessories

Open top cable supports shall be utilized as a pathway for communication cabling. The J Hook cable supports shall be manufactured from a non-conductive material suitable for use in air-handling spaces. The cable support must maintain complete horizontal and vertical four times the O.D. bend radius control and must manage up to 50 four-pair UTP cables. The system must allow for the ability to add future cable routing capacity. The cable support must provide the ability to retain the cable bundle with *TAK-TY*[®] Hook & Loop Cable Ties or AVP of Computing Infrastructure approved equivalent.

Part Number	Description	Material*	Maximum Static Load (Lbs.)
JMJH2W-X20‡	J Hook for wall mount applications	Nylon	30
JMJH2-X20‡	J Hook for use with brackets	Nylon	30
JMCB-X	Chaining Bracket	Galvanized Steel	120

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

JMCMB25-1-X	Ceiling Mount Bracket – 1 level	Galvanized Steel	180
JMCMB25-3-X**	Ceiling Mount Bracket – 3 level	Galvanized Steel	180
JMDWB-1-X	Drop Wire Bracket – 1 level	Galvanized Steel	20
JMDWB-3-X**	Drop Wire Bracket – 3 level	Galvanized Steel	40
JMTRB38-1-X	Threaded Rod Bracket – 1 level	Galvanized Steel	180
JMTRB38-3-X**	Threaded Rod Bracket – 3 level	Galvanized Steel	180
JMSBCB87-1-X	Screw-on Beam Clamp Bracket – 1 level	Galvanized Steel	180
JMSBCB87-3-X**	Screw-on Beam Clamp Bracket – 3 level	Galvanized Steel	180

** Not for use with chaining brackets.

‡ Available in natural and black.

* Suitable for use in air handling spaces per UL 2043. Listed in accordance with CAN/ULC S102.2 when mounted as single units or in pairs. Minimum spacing of 4 ft. (1220mm) required between mount points. (Flame Spread Rating = 0, Smoke Developed Classification = 30).

5.3.7. Cable Support System

Open top cable supports shall be utilized as a pathway for communication cabling. The J Hook cable supports shall be manufactured from a non-conductive material suitable for use in air-handling spaces. The pre-riveted J Hook assemblies must maintain complete horizontal and vertical four times the O.D. bend radius control and must manage up to 50 four-pair UTP cables. The cable support must provide the ability to retain the cable bundle with *TAK-TY*® Hook & Loop Cable Ties or AVP of Computing Infrastructure approved equivalent.

Part Number	Description	Material*	Max. Static Load (Lbs.)
JP2W-L20	J Hook for wall mount applications only. One ¼” (M6) mounting hole for user supplied screw.	Nylon	30
JP2CM-L20	J Hook with ceiling mount bracket that has one 3/16” (M5), ¼” (M6), and 3/8” (M10) mounting hole.	Nylon J Hook with metal attachments	30
JP2DW-L20	J Hook with clip for use with #12 wire, threaded rod up to 3/8” in diameter, or 1/8” – 3/8” thick flanges.	Nylon J Hook with metal attachments	10
JP2SBC50-L20	J Hook with screw-on beam clamp for use with flanges up to ½” thick.	Nylon J Hook with metal attachments	30
JP2SBC50R-L20	J Hook with screw-on beam clamp for use with flanges up to ½” thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

JP2HBC25R-L20	J Hook with hammer-on beam clamp for use with flanges 1/8" – 1/4" thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30
JP2HBC50R-L20	J Hook with hammer-on beam clamp for use with flanges 5/16" – 1/2" thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30
JP2HBC75R-L20	J Hook with hammer-on beam clamp for use with flanges 9/16" – 3/4" thick. Rotates 360 degrees.	Nylon J Hook with metal attachments	30
JP2ZP-L20	J Hook with z-purlin clip for use with angled flanges up to 1/4" thick.	Nylon J Hook with metal attachments	30
JP2CP-L20	J Hook with c-purlin clip for use with vertical flanges up to 1/4" thick.	Nylon J Hook with metal attachments	30
JP2UF100-L20	J Hook with under floor pedestal support clamp for use with pedestal support up to 1" in diameter.	Nylon J Hook with metal attachments	30

* Suitable for use in air handling spaces per UL 2043. Listed in accordance with CAN/ULC S102.2 when mounted as single units or in pairs. Minimum spacing of 4 ft. (1220mm) required between mount points. (Flame Spread Rating = 0, Smoke Developed Classification = 30).

5.3.8. Fiber Routing Systems

FIBER-DUCT

Materials

The system must be listed to UL 2024A Optical Fiber Routing Assemblies and utilize material, which exhibits flame resistant characteristics, tested in accordance with UL94V-0.

Channel

Fittings

Mounting

Part Number	Description	Color	Size
	FIBER-DUCT	Orange (M.M.)	1" I.D.
	FIBER-DUCT Slotted	Orange (M.M.)	1" I.D.

** Denotes color

5.3.9. Rack Equipment

Standard Equipment Rack

The telecommunications rack shall be constructed of extruded aluminum and capable of accepting 19" wide EIA equipment. Rack construction method shall ensure an electrically bonded structure for ease of grounding. The rack shall be UL listed for 1,000 lbs. load rating. The equipment mounting rails shall be double-sided #12-24 EIA universal mounting hole spacing. The equipment mounting rails shall include printed rack space identification on the front and back and be numbered from top to bottom. The channel of

FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

the rack shall be capable of mounting NETRUNNERTM or PATCHRUNNERTM Vertical Cable Managers. 24 #12-24 mounting screws shall be included with the rack.

Part Number	Description	Color
CMR19x84	Standard 19"x 84" 2 Post Equipment Rack	Black

FLORIDA STATE COLLEGE AT JACKSONVILLE INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

6. Backbone Cabling System

The Backbone Cable Subsystem in a building is the part of the premises distribution system that provides connection between equipment rooms, telecommunication rooms, and telecommunications service entrance facilities. A backbone subsystem provides either intra-building connections between floors in multi-story buildings or inter-building connections in campus-like environments.

All cables shall be run using a star topology (home run) from the Main Cross-Connect (MC) to each Horizontal Cross-Connect (HC) within the telecommunications room. One additional Intermediate Cross-Connect (IC) may be implemented between the MC and HC if so required. The length of each individual run of backbone fiber cable shall not exceed 2000 meters for multimode and 3000 meters for singlemode and the length of each UTP cable run for voice applications is not to exceed 800 meters (90 meters for data) as specified under TIA/EIA-568-B. The length of the media between the IC and HC shall not exceed 300 meters.

The type of backbone copper cable shall be General Cable 100 Ω unshielded twisted pair (UTP), multi-pair cable. The type of backbone fiber cable shall be 50/125 μm multimode fiber cable or 8.3/125 μm singlemode fiber cable. The bending radius and maximum pulling tension of the cable shall be adhered to during handling and installation.

6.1 Voice Backbone

Voice Cable

- Multi-pair copper cable shall be used and shall be listed per NEC Article 800.51.
- All cable shall meet or exceed the following specifications.

6.1.1.1. Multi-pair Category 5e UTP Cable

The Multi-pair Category 5e cable shall be General Cable CMR or CMP rated. These requirements are for cables of 25 unshielded twisted pairs of 24 AWG bare copper. 24 pairs stranded around a jacketed unit of the 25th pair to make the 25 pair cable. These components shall be stranded together and enclosed by an overall jacket.

All cable shall conform to the requirements for communications circuits defined by the National Electrical Code (Article 800) and the Canadian Building Code. All cable shall be listed to NEC Article 800-51(b).

The cable manufacturer shall be ISO 9001/TL 9000 registered.

Voice Termination and Cross-connects

The *PANDUIT*[®] *MINI-COM*[®] Network Cabling System or approved equivalent shall be used for the Backbone subsystem, including all modular connectors. The network cabling system shall be comprised of modular connectors in support of high-speed networks and applications designed for implementation on copper cabling.

FLORIDA STATE COLLEGE AT JACKSONVILLE

INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

All outlets shall utilize fully interchangeable and individual connector modules that mount side-by-side to facilitate quick and easy moves, adds, and changes.

6.1.1.2. Modular Patch Panels and Cords

Four-pair Category 6 UTP cabling shall be terminated onto a four-pair Category 6 modules. All modules shall be terminated using the T568B wiring scheme. The eight position modular jacks shall exceed the connector requirements of the TIA/EIA Category 6 standard. The module termination to four-pair 23 AWG 100 ohm solid unshielded twisted pair cable shall be accomplished by use of a forward motion termination cap and shall not require the use of a punchdown tool.

MINI-COM® Angled High Density Modular Patch Panels shall quadruple patch panel density. The angled design shall minimize the need for horizontal cable managers while the high-density patch panels shall provide 48 ports per rack space. Together these features shall provide the capacity of 48 ports in one rack space vs. 24 ports in two rack spaces.

Part Number	Flat/Angled	Number of Ports	Rack Spaces
CPPA48HDWBL	A	48	1

MINI-COM® Flush Mount Modular Patch Panels shall be of metal design with rear-mounted faceplates allowing modules to be flush with the front of the patch panel. There shall be pre-printed numbers above each port for easy identification and white write on areas for port and/or panel identification on the 24 and 48 port version. Panels shall be available in flat and angled versions. Angled panels facilitate proper bend radius control and minimize the need to horizontal cable managers.

Part Number	Flat/Angled	Number of Ports	High Density	Number of Rack Spaces
CPPA48FMWBL	A	48		2

6.2. Data Backbone

Data Cable

All backbone fiber optic cable shall be a 48 strand General Cable 50/125µm tight buffered multimode or General Cable 8.3/125 µm jacketed singlemode fiber optic cable. Fiber cable shall be riser (OFNR) or plenum (OFNP) listed where applicable.

Data Termination and Cross Connects

6.2.1. Fiber Connectors and Patch Cords

MINI-COM® *LC*® Duplex Jack Modules and Plugs

Fiber optic connectors

LC small form factor (SFF) field polish connectors with rear pivot latch shall be TIA/EIA-604 FOCIS-10 compatible. LC simplex and duplex connectors shall be field terminable. The fibers shall terminate in 1.25mm ceramic ferrules with non-optical disconnect functionality and an average insertion loss of 0.1dB per mated pair for multimode and singlemode fiber.

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

Standards requirements: TIA/EIA-604 FOCIS-10 compatible; exceeds TIA/EIA-568-B.3 requirements

Split sleeve material: Phosphor bronze or zirconia ceramic (required for singlemode applications)

Insertion loss: .1dB average (multimode and singlemode); supports the performance of FOCIS-10 compliant connectors/patch cords

Return loss: Supports singlemode (>40dB for SPC and >55dB for UPC) and multimode (>20dB) connector polish performance

Part Number	Description
FLCDM900EIY	LC mm Dupl Connector With 900µm Boots - Field Polish
FLCDMEIY	LC Dupl Multimode Fiber Optic Connector - Field Polish
FLCDSBUY	LC Dupl Singlemode Fiber Optic Connector - Field Polish
FLCSMEIY	LC Simpl Multimode Fiber Optic Connector - Field Polish

Part Number				
FLCSMEIY	Simplex	900µm buffered fiber and 1.6mm – 2.0mm jacketed cable	Multimode	Zirconia Ceramic
FLCSM3.0EI	Simplex	3.0mm jacketed cable		
FLCDMEIY	Duplex	1.6mm – 2.0mm jacketed cable		
FLCDM900EIY	Duplex	900µm buffered fiber		
FLCDM3.0EI	Duplex	3.0mm jacketed cable		
FLCSSBUY	Simplex	900µm buffered fiber and 1.6mm – 2.0mm jacketed cable	Singlemode	Zirconia Ceramic
FLCSS3.0BU	Simplex	3.0mm jacketed cable		
FLCDSBUY	Duplex	1.6mm – 2.0mm jacketed cable		
FLCDS900BUY	Duplex	900µm buffered fiber		
FLCDS3.0BU	Duplex	3.0mm jacketed cable		

7. Identification

7.1. Patch Panels and Communications Outlets

- 7.1.1. All cabling is to be identified using the ANSI/TIA/EIA 606A standard, whereby each outlet jack is completely identified by the originating TR, patch panel, port, and the additional Room identifier (i.e. TR1-1-01-100-A). Each room identifier shall be a unique designation consisting of the space number where the outlet is located and a sequentially incrementing suffix letter for each outlet connector located in the space (i.e. 100-A, 100-B, etc.). Identification of the outlets is to be done in a clockwise order around the room from the main entrance, beginning with A (100-A, 100-B, etc.). Floor boxes are to be done in the same manner except they are preceded by an FB (FB100-A, FB100-B, etc.). Circuits installed in ceiling spaces for Cameras and Access points shall be identified as above except the room identifier shall be preceded with a CB (CB100-A, CB100-B, etc.).
- 7.1.2. Labels shall be nominal 3/8-inch high, 2/3-inch wide, machine printed, self-laminating, vinyl labels with white background and black text. Attach labels directly on/or adjacent to respective connector.
- 7.1.3. Rooms are to be arranged in sequential order on the patch panels. Misordered and/or mislabeled cables will have to be reordered in proper sequence and retested.
- 7.1.4. The complete identifier is to be used for test identification purposes. If all components have been properly labeled the sequence should be simple to create.
- 7.1.5. All patch panel labels shall be made as a single group of six. Do not make individual labels for patch panel ports.
- 7.1.6. The complete identifier is to be used for test identification purposes. If all components have been properly labeled the sequence should be simple to create.

**All patch panel labels shall be made as a single group of six.
Do not make individual labels for patch panel ports.**

Format: BB-TR rrr - R rr - PP - O - rrr - X

BB...Building Number

TR rrr...TR room number

R rr...Rack Number (if more than one)

PP...Patch Panel number

O...Outlet Number

rrr...Room Number

X...Jack Position Letter

i.e. - B1-TRE110-R1-1-01-100-A

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

8. Testing Data

Required Testing for System Warranty

The PanGen System Warranty and the Certification Plus System Warranty are based on industry standards; therefore, as a move forward, *PANDUIT*® will only be accepting the following configurations for Category 6.

Beginning July 1st, 2004, all copper tests should be compliant to current EIA/TIA standards: Perm Link or Channel. *PANDUIT*® will no longer accept Basic Link tests for warranty*.

All testing must utilize the correct adapter and test. Any deviation from the table below will result in re-testing the network.

<u>Approved Test Leads For PANDUIT Mini-Com® TX6™</u>							
<u>PLUS Jack Modules and DP6™ PLUS Patch Panels</u>							
Approved: Panduit independently verifies field testers report values consistent with a Laboratory Network Analyzer for adherence to the standards. The following testers are fully approved:							
Permanent Link							
	Firmware Version	Software Version	Calibration Equipment	Autotest	Test Leads	Personality Module	Comments
Fluke: Networks DSP-4000 Series Cable Analyzer (www.flukenetworks.com)	DSP-4300 ¹ Software: V1.906 Standards: V5.12 DSP-4100 ¹ Software: V4.906 Standards: V5.12 DSP-4000 ¹ Software: V3.906 Standards: V5.12	Linkware Software V2.1	Part # DSP-PCAL Universal Permanent Link Calibration Kit ²	TIA Cat 6 Perm. Link	Part # DSP-LIA101 Universal Permanent Link Interface Adapter	PM06 ³	1. Consult Fluke Networks' web site for the latest Firmware and Software Version. 2. It is STRONGLY RECOMMENDED that the DSP-LIA101 Adapters are calibrated using this Kit and the Linkware Software (DSP Utilities/ Permanent Link Cal.) prior to Permanent Link testing. 3. The PM25 may also be used to test Panduit TP jacks and DP6 PLUS panels.
Fluke: Networks DTX-1800 Series Cable Analyzer (www.flukenetworks.com)	Software: V1.00	Linkware Software V2.1	-	TIA Cat 6 Perm. Link	Part # DTX-PLA001 Universal Permanent Link Interface Adapter	PM06 ³	1. Consult Fluke Networks' web site for the latest Firmware and Software Version. 2. It is STRONGLY RECOMMENDED that the tester is calibrated prior to testing. 3. The PM25 may also be used to test Panduit TP jacks and DP6 PLUS panels.
Agilent: N2600A WireScope 350 N2610A FrameScope 350 (www.agilent.com/comms/)	WireScope Software 3.1 or later	WireScope Software 3.1 or later ¹	Part # N2604A-301 Precision Calibration Cable ²	Category 6: Link	Part # N2604A-101 Universal Cat 6 Link Smartprobe ⁴	N/A	1. Consult Agilent's web site for the latest Software Version. 2. Calibration with the Precision Calibration Cable is STRONGLY RECOMMENDED . 3. Tester holds last calibration. Tester must be recalibrated for switching testing from Channel to PL. 4. Universal Cat 6 Link Smartprobe should be in optimal condition. See owners manual.
Ideal: LANTEK 6 LANTEK 7 (www.idealindustries.com)	Firmware: V2.000	LANTEK Reporter V3.009	UTPSP17 or UTPSP7	Twisted Pair Perm: Cat 6-250	Part # 0012-00-0629 Category 6/5e adapter RJ45	N/A	1. Consult Ideal's web site for the latest Firmware and Software Version. 2. Tester must be recalibrated from job site to job site. 3. Patch cords should be in optimal condition.

FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

Channel							
Fluke: Networks DSP-4000 Series Cable Analyzer (www.flukenetworks.com)	DSP-4300 ¹ Software: V1.906 Standards: V5.12 DSP-4100 ¹ Software: V4.906 Standards: V5.12 DSP-4000 ¹ Software :V3.906 Standards: V5.12	Linkware Software V2.1	-	TIA Cat 6 Channel	Part # DSP- LIA012 Category 6/5e Channel Adapters or Part # DSP- LIA013 Cat 6 Channel/Traffic Adapter	N/A	1. Consult Fluke Networks' web site for the latest Firmware and Software Version.
Fluke: Networks DTX-1800 Series Cable Analyzer (www.flukenetworks.com)	Software: V1.00	Linkware Software V2.1	-	TIA Cat 6 Channel	Part # DTX- CHA001 Cat 6 / Class E Channel Adapter	N/A	1. Consult Fluke Networks' web site for the latest Firmware and Software Version. 2. It is STRONGLY RECOMMENDED that the tester is calibrated prior to testing.
Agilent: N2600A WireScope 350 N2610A FrameScope* 350 (www.agilent.com/comms/)	WireScope Software 3.1 or later	WireScope Software 3.1 or later ¹	UTPSP17 or UTPSP7	Category 6: Channel	Part # N2604A- 100 Universal Cat 6 Channel Smartprobe ¹	N/A	1. Consult Agilent's web site for the latest Software Version. 2. Tester holds last calibration. Tester must be recalibrated for switching testing from PL to Channel.
Ideal: LANTEK 6 LANTEK 7 (www.idealindustries.com)	Firmware: V2.000	LANTEK Reporter V3.009	UTPSP17 or UTPSP7	Twisted Pair Channel: Cat 6-250	Part # 0012-00- 0629 Category 6/5e adapter RJ45	N/A	1. Consult Ideal's web site for the latest Firmware and Software Version. 2. Tester must be recalibrated from job site to job site. 3. Patch cords should be in optimal condition.
* Panduit has not physically tested the FrameScope 350. Agilent maintains the FrameScope and WireScope have identical software and hardware for cabling testing.							

FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS

Accepted Test Leads For PANDUIT Mini-Com® TX6™

PLUS Jack Modules and DP6™ PLUS Patch Panels

Accepted: Panduit independently tests field testers for adherence to the standards. The following testers reporting passing values will be accepted:

Permanent Link							
	Firmware Version	Software Version	Calibration Equipment	Autotest	Test Leads	Personality Module	Comments
Fluke: Networks OMNISCanner 2 www.flukenetworks.com	Version 6.11	Linkware Software V1.2	-	Cat 6 Link	<u>Part# OMNI-LIA101</u> Universal Permanent Link Interface Adapter	PM06	1. The PM25 may also be used to test Panduit TP jacks and DP6 PLUS panels.
Channel							
	Firmware Version	Software Version	Calibration Equipment	Autotest	Test Leads	Personality Module	Comments
Fluke: Networks OMNISCanner 2 www.flukenetworks.com	Version 6.11	Linkware Software V1.1	-	Cat 6 Chan ¹	<u>Part# 8262-42</u> Category 5/5e/6 Channel Adapter ²	N/A	1.IMPORTANT: Make sure Channel adapters are used with Channel Autotests. 2. Testing Channel on drops less than 20m is NOT RECOMMENDED .

**FLORIDA STATE COLLEGE AT JACKSONVILLE
INFORMATION TRANSPORT SYSTEM SPECIFICATIONS**

9. Appendixes:

9.1. Appendix 7

Renamed Section 7 from Additional Documentation to Identification.
Section Covers Patch Panel and Outlet Labeling